

The Enforcement Respo
- PWS Ranking using Sum of (

Scores above the following threshold are highlighted 11
10/1/2019

EPA Region	State	PWSID	PWS Name	ETT Score	Sys has HB viols?	PWS Type
05	MI	MI0040609	PINE HAVEN ESTATES	26	Y	CWS
05	MI	MI0004596	MYSTIC VIEW APARTMENTS	20	Y	CWS
05	MI	MI0003520	KALAMAZOO	11	Y	CWS

nse Policy Targeting Tool
(S1 + S2 + S3 + ...) + n Formula -

Database: Oct 2019 SDWIS/FED Freeze
 (For most states, this includes data up to Jun 30, 2019.)

Pop Srvd	Priority Since Date	Repeat Violator Tool	Total Unresolved Points	On Path to Compliance ?	School or Childcare	Owner Type Code	Last Lead 90% result (mg/L)	Num Lead ALEs 5 yrs
125	03/31/2019	27	25	Not on Path	N	P		
100	09/30/2019	30	20	New	N	P		
150000	06/30/2019	10	10	Not on Path	N	L	0.013	

State Update

ACO signed 11/1/2019 (SFL code submitted with Nov 2019 quarterly reporting). System pursuing radium removal treatment. Permit application received 12/20/2019.

Supply returned to compliance July 2019. Treatment installed.

Supply is having some difficulty meeting designated WQP ranges in portions of the system. Supply is planning a CCT study. EGLE is evaluating next steps in the enforcement process.